



PUBLIC HEALTH ENGINEERING DEPARTMENT
LABORATORY JHUNJHUNU

CHEMICAL EXAMINATION REPORT OF WATER

No. Lab. / Chem. /2025-26/ 259

Date - 24-6-2025

To,
The secretary
Central Academy Shiksha Samiti
Gudha Gorji
Ref- Your letter no. 2025/sp 1 dated 24-06-2025

District - Jhunjhunu
Tehsil:- Udaipurwati

Date of Exam -24--06-2025

A	Name & Location of Source	IS-10500:2012		Water Sample MG Global School Chanwara Road
B	Village/ Town			Gudha Gorji
C	Date Of Collection			24-06-2025
D	Lab. Sample No.			C-42
Sr. No	Parameters	Desirable limits	Permissible limits	Value
1	pH	6.5—8.5	6.5—8.5	6.62
2	Turbidity[NTU]	1	5	Nil
3	Temperature[C]	-----	-----	25
4	Colour[Units]	5 Hazen Unit	15 Hazen Unit	None
5	Odour	Unobjectionable	Unobjectionable	Unobj.
6	Residual Chlorine	0.2	1.0	Nil
7	Total Alkalinity[asCaCO ₃]	200	600	48
8	Total Hardness[asCaCO ₃]	200	600	36
9	Chloride[asCl ⁻¹]	250	1000	28
10	Nitrate[as NO ₃ ⁻¹]	45	45	04
11	Fluoride [as F ⁻¹]	1.0	1.5	0.23
12	Sulphate [as SO ₄ ⁻²]	200	400	10
13	TDS	500	2000	182

Note:1- All Results Except pH in mg/L.

2- This report is not valid for legal cases/legal purposes.

(S K Sharma)

(S K Sharma)
Junior Chemist

PHED Laboratory Jhunjhunu

मनीराम
सचिव
केंद्रल अकादमी शिक्षा समिति
बुध गौरजी जिला इन्सुन (राज.) १३३००१

Asha Birla
PRINCIPAL
MG GLOBAL SCHOOL
GUDHA GORJI, J.JN. (RAJ.)

SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 261

Dated: 25-6-2025

It is certified that an inspection team headed by Surender Kumar Sharma
..... Junior chemist from PHED
..... Laboratory, Jhunjhunu PHED inspected the MG GLOBAL SCHOOL,
CHANWARA ROAD, GUDHA GORJI, JHUNJHUNU on 25-6-2025 and on the
basis of Water Test Report (Attached) bearing no. 259
dated. 24-6-2025 of PHED Lab Jhunjhunu (PHED Lab) certified
that the MG Global School has safe drinking water facilities for the students and members of
staff of the institution. School is also maintains the hygienic sanitation condition in the
school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt. This
certificate is valid till 24-6-2026

Signature with Seal:

Name : (सुरेन्द्र कुमार शर्मा)

Designation : कनिष्ठ रसायनज्ञ
जन स्वास्थ्य अभि० विभाग

Name & Address of the Office / Department प्रशा. शाला, झुंझुनू,

To
MG GLOBAL SCHOOL,
CHANWARA ROAD, GUDHA GORJI, JHUNJHUNU

मनीराम

सचिव
उत्तर अकादमी शिक्षा समिति
गुडा गौड़जी जिला झुंझुनू (राज.) 333027

Asua Singh

PRINCIPAL
MG GLOBAL SCHOOL
GUDHA GORJI, JHUNJHUNU (RAJ.)